



Government Of West Bengal
Office Of The Divisional Fire Officer, South Dinajpur
West Bengal Fire & Emergency Services
Raiganj Fire Station, College Para, P.O.- Raiganj, Pin :- 733134

Memo no.:WBVES/NZ/FP/1051/16

Date: 17-10-2023

From:
Divisional Fire Officer, South Dinajpur
West Bengal Fire & Emergency Services

To: Azad D Ed Training College
Vill.- Samsia, P.O.- Nahit, P.S.- Kushmandi, Dist.- Dakshin Dinajpur. PIN- 733132

Sub: Issuance of Fire Safety Certificate for Existing construction of G+2 Storied Educational Building in the name of "AZAD D.Ed. TRAINING COLLEGE"; at Village – Samsia, Mouza – Bateswar, J.L. No. 73, Khasara No. 710, Plot No. 193, 219, 226, 229 & 235 under 1 No. Akcha Gram Panchayat, PO. Nahit, PS. Kushmandi, Dist. Dakshin Dinajpur, PIN. 733132, West Bengal.

This is in reference to your application no. 0125189230700024 dated 13-10-2023 regarding the Issuance of Fire Safety Certificate for Existing construction of G+2 Storied Educational Building in the name of "AZAD D.Ed. TRAINING COLLEGE"; at Village – Samsia, Mouza – Bateswar, J.L. No. 73, Khasara No. 710, Plot No. 193, 219, 226, 229 & 235 under 1 No. Akcha Gram Panchayat, PO. Nahit, PS. Kushmandi, Dist. Dakshin Dinajpur, PIN. 733132, West Bengal.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

- 1) Driveway of the G + 2 Educational Building must be free of any type of obstruction for easy movement of Fire Appliances. No Parking will be allowed on the drive way.
- 2) The interior finish decoration of the Educational Building ("AZAD D.Ed. TRAINING COLLEGE") shall be made with low flame spread materials conforming to the I.S. Specification.
- 3) To eliminate risk of fire hazards, good housekeeping both for inside and outside of the G + 2 storied Educational (AZAD D.Ed. TRAINING COLLEGE) building shall be strictly maintained.
- 4) Existing electrical wiring of the whole Educational ("AZAD D.Ed. TRAINING COLLEGE") Building shall have to be carefully checked for any wear and tear in them. If require the old electrical lines shall be replaced with new electrical lines, cables shall always be laid in M.S conduit pipes continuously bonded to the earth.
- 5) The notice of Fire Fighting and Evacuation from the G + 2 storied Educational ("AZAD D.Ed. TRAINING COLLEGE") Building shall be prepared and displayed at all venerable of the building.

- 6)The employee and security staff shall be conversant with installed Fire Fighting equipment (i.e., Fire Extinguisher) of the Educational ("AZAD D.Ed. TRAINING COLLEGE") Building and to operate in the event of Fire and Testing.
- 7)Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
- 8)First-Aid Firefighting system shall be provided as per I.S. Specifications.
- 9)Arrangement shall have to be made for regular checking, testing and maintenance of all the firefighting installation in the G + 2 storied Educational Building to keep them to perfectly good working condition at all times.
- 10)The Fire Safety Certificates is valid for Three years and has to be renewed after three years from the date of issue of this letter. As per Govt. of West Bengal Vide Notification No- 629_L, Dated-17-04-2018.

Signature valid

Digitally Signed
Name: SHIBA NANDA GUPTA
Date: 17-Oct-2023 10:17:02
Reason: Approved
Location: West Bengal

Divisional Fire Officer, South Dinajpur
West Bengal Fire & Emergency Services

Memo No.: WBFES/NZ/FP/1057/16